

Client : DATA DISCO
: 29 ELM CLOSE
: BROADCLYST
: EXETER DEVON

Location : 29 ELM
:
:
:

Test Date: 15/08/2009 Test Time: 15:47 User: PETE
Appliance: 034 RADIO MIC MIXER

Visual Inspection P
Bond/Cont1 0.057 Ohm P
Bond/Cont2 0.057 Ohm P
Bond/Cont3 0.058 Ohm P
Insulation >50.0 MEG P
Operation 0.020 kVA P
Earth Leak 0.860 mA P

Test Date: 15/08/2009 Test Time: 15:50 User: PETE
Appliance: 035 PC MIXER SYSTEM 2

Visual Inspection P
Bond/Cont1 0.143 Ohm P
Bond/Cont2 0.147 Ohm P
Bond/Cont3 0.144 Ohm P
Insulation >50.0 MEG P
Operation 0.019 kVA P
Earth Leak 0.190 mA P

Test Date: 15/08/2009 Test Time: 15:59 User: PETE
Appliance: 036 IEC SPLITTER

Visual Inspection P
Extension Lead P
Bond/Cont1 0.112 Ohm P
Bond/Cont2 0.108 Ohm P
Bond/Cont3 S
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 16:01 User: PETE
Appliance: 037 IEC SPLITTER

Visual Inspection P
Extension Lead P
Bond/Cont1 0.110 Ohm P
Bond/Cont2 0.111 Ohm P
Bond/Cont3 0.111 Ohm P
Insulation >50.0 MEG P

Signature: PL Newman Date: 15/8/09

Test Date: 15/08/2009 Test Time: 16:08 User: PETE
Appliance: 038 (21)0035497059 MAGNUM 850 SMOKE
Visual Inspection P
Bond/Cont1 0.039 Ohm P
Bond/Cont2 0.039 Ohm P
Bond/Cont3 0.039 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.140 mA P


Test Date: 15/08/2009 Test Time: 16:12 User: PETE
Appliance: 039 (21)0035497071 MAGNUM 850 SMOKE
Visual Inspection P
Bond/Cont1 0.046 Ohm P
Bond/Cont2 0.046 Ohm P
Bond/Cont3 0.045 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 16:23 User: PETE
Appliance: 040 SPECTRA BANK 6
Visual Inspection P
Bond/Cont1 0.049 Ohm P
Bond/Cont2 0.048 Ohm P
Bond/Cont3 0.046 Ohm P
Insulation >50.0 MEG P
Operation 0.009 kVA P
Earth Leak 0.260 mA P

Test Date: 15/08/2009 Test Time: 16:25 User: PETE
Appliance: 041 SPECTRA BANK 6
Visual Inspection P
Bond/Cont1 0.046 Ohm P
Bond/Cont2 0.046 Ohm P
Bond/Cont3 0.044 Ohm P
Insulation >50.0 MEG P
Operation 0.010 kVA P
Earth Leak 0.270 mA P

Test Date: 15/08/2009 Test Time: 14:17 User: PETE
Appliance: 001 IEC 13A LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.062 Ohm P
Bond/Cont2 0.061 Ohm P
Bond/Cont3 0.062 Ohm P
Insulation >50.0 MEG P

Signature: _____

Date: 15/8/09

Test Date: 15/08/2009 Test Time: 14:20 User: PETE
Appliance: 002 IEC-13A LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.073 Ohm P
Bond/Cont2 0.072 Ohm P
Bond/Cont3 0.073 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:22 User: PETE
Appliance: 003 IEC-IEC LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.137 Ohm P
Bond/Cont2 0.137 Ohm P
Bond/Cont3 0.137 Ohm P
Insulation >50.0 MEG P


Test Date: 15/08/2009 Test Time: 14:24 User: PETE
Appliance: 004 IEC-13A LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.082 Ohm P
Bond/Cont2 0.080 Ohm P
Bond/Cont3 0.080 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:26 User: PETE
Appliance: 005 13A-4WAY EXT
Visual Inspection P
Extension Lead P
Bond/Cont1 0.103 Ohm P
Bond/Cont2 0.104 Ohm P
Bond/Cont3 0.102 Ohm P
Insulation >50.0 MEG P


Test Date: 15/08/2009 Test Time: 14:27 User: PETE
Appliance: 006 13A-6WAY EXT
Visual Inspection P
Extension Lead P
Bond/Cont1 0.232 Ohm P
Bond/Cont2 0.225 Ohm P
Bond/Cont3 0.226 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:33 User: PETE
Appliance: 007 13A-NEUTRIK
Visual Inspection P
Extension Lead P
Bond/Cont1 0.230 Ohm P
Bond/Cont2 S
Bond/Cont3 S
Insulation >50.0 MEG P

Signature: _____



Date: _____



Test Date: 15/08/2009 Test Time: 14:32 User: PETE
Appliance: 008 13A-NEUTRIK
Visual Inspection P
Extension Lead P
Bond/Cont1 0.234 Ohm P
Bond/Cont2 S
Bond/Cont3 S
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:31 User: PETE
Appliance: 009 13A-NEUTRIK
Visual Inspection P
Extension Lead P
Bond/Cont1 0.234 Ohm P
Bond/Cont2 S
Bond/Cont3 S
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:34 User: PETE
Appliance: 010 LIGHT CONTROL SYSTEM
Visual Inspection P
Bond/Cont1 0.179 Ohm P
Bond/Cont2 0.145 Ohm P
Bond/Cont3 0.140 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 14:40 User: PETE
Appliance: 011 13A-16A ARCTIC LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.081 Ohm P
Bond/Cont2 S
Bond/Cont3 S
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:42 User: PETE
Appliance: 012 13A-16A ARCTIC LEAD
Visual Inspection P
Extension Lead P
Bond/Cont1 0.078 Ohm P
Bond/Cont2 0.072 Ohm P
Bond/Cont3 S
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 15:07 User: PETE
Appliance: 023 15000061 EVL MINI SPOT
Visual Inspection P
Bond/Cont1 0.053 Ohm P
Bond/Cont2 0.051 Ohm P
Bond/Cont3 0.050 Ohm P
Insulation >50.0 MEG P
Operation 0.328 kVA P
Earth Leak 0.000 mA P
Signature: PL Newman Date: 15/8/09

Test Date: 15/08/2009 Test Time: 15:10 User: PETE
 Appliance: 024 13A-IEC
 Visual Inspection P
 Extension Lead P
 Bond/Cont1 0.046 Ohm P
 Bond/Cont2 0.046 Ohm P
 Bond/Cont3 0.046 Ohm P
 Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 15:12 User: PETE
 Appliance: 025 15000067 EVL MINI SPOT
 Visual Inspection P
 Bond/Cont1 0.043 Ohm P
 Bond/Cont2 0.042 Ohm P
 Bond/Cont3 0.042 Ohm P
 Insulation >50.0 MEG P
 Operation 0.250 kVA P
 Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 15:18 User: PETE
 Appliance: 026 115011 MC2 T1500 AMP
 Visual Inspection P
 Bond/Cont1 0.130 Ohm P
 Bond/Cont2 0.143 Ohm P
 Bond/Cont3 0.113 Ohm P
 Insulation >50.0 MEG P
 Operation 0.061 kVA P
 Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 15:37 User: PETE
 Appliance: 029 13A-IEC
 Visual Inspection P
 Extension Lead P
 Bond/Cont1 0.062 Ohm P
 Bond/Cont2 0.061 Ohm P
 Bond/Cont3 0.061 Ohm P
 Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 15:38 User: PETE
 Appliance: 030 IEC-IEC
 Visual Inspection P
 Extension Lead P
 Bond/Cont1 0.130 Ohm P
 Bond/Cont2 0.129 Ohm P
 Bond/Cont3 0.129 Ohm P
 Insulation >50.0 MEG P

Signature: PL Newman Date: 15/8/09

Test Date: 15/08/2009 Test Time: 15:43 User: PETE
Appliance: 032 EVL MICRO OCONTROLLE
Visual Inspection P
Bond/Cont1 0.142 Ohm P
Bond/Cont2 0.141 Ohm P
Bond/Cont3 0.141 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 15:40 User: PETE
Appliance: 031 PC MIXER SYSTEM 1
Visual Inspection P
Bond/Cont1 0.181 Ohm P
Bond/Cont2 0.172 Ohm P
Bond/Cont3 0.169 Ohm P
Insulation >50.0 MEG P
Operation 0.019 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 14:36 User: PETE
Appliance: 013 IEC-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.139 Ohm P
Bond/Cont2 0.136 Ohm P
Bond/Cont3 0.135 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:49 User: PETE
Appliance: 014 IEC-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.119 Ohm P
Bond/Cont2 0.119 Ohm P
Bond/Cont3 0.117 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:50 User: PETE
Appliance: 015 IEC-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.116 Ohm P
Bond/Cont2 0.117 Ohm P
Bond/Cont3 0.114 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:52 User: PETE
Appliance: 016 13A-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.069 Ohm P
Bond/Cont2 0.070 Ohm P
Bond/Cont3 0.069 Ohm P
Insulation >50.0 MEG P
Signature: PL Newman Date: 15/8/09

Test Date: 15/08/2009 Test Time: 14:55 User: PETE
Appliance: 017 13A-4WAY EXT
Visual Inspection P
Extension Lead P
Bond/Cont1 0.096 Ohm P
Bond/Cont2 0.095 Ohm P
Bond/Cont3 0.096 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:56 User: PETE
Appliance: 018 13A-13A 2 WAY EXT
Visual Inspection P
Extension Lead P
Bond/Cont1 0.266 Ohm P
Bond/Cont2 0.265 Ohm P
Bond/Cont3 0.265 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 14:58 User: PETE
Appliance: 019 STROBE
Visual Inspection P
Bond/Cont1 0.088 Ohm P
Bond/Cont2 0.087 Ohm P
Bond/Cont3 0.087 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 15:01 User: PETE
Appliance: 020 STROBE
Visual Inspection P
Bond/Cont1 0.088 Ohm P
Bond/Cont2 0.088 Ohm P
Bond/Cont3 0.088 Ohm P
Insulation >50.0 MEG P
Operation 0.000 kVA P
Earth Leak 0.000 mA P

Test Date: 15/08/2009 Test Time: 15:03 User: PETE
Appliance: 021 IEC-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.112 Ohm P
Bond/Cont2 0.113 Ohm P
Bond/Cont3 0.114 Ohm P
Insulation >50.0 MEG P

Test Date: 15/08/2009 Test Time: 15:04 User: PETE
Appliance: 022 IEC-IEC
Visual Inspection P
Extension Lead P
Bond/Cont1 0.129 Ohm P
Bond/Cont2 0.128 Ohm P
Bond/Cont3 0.128 Ohm P
Insulation >50.0 MEG P
Signature: PL Newman Date: 15/8/09

Test Date: 15/08/2009 Test Time: 15:32 User: PETE
Appliance: 027 21022 T1000 PANARAY CONT
Visual Inspection P
Bond/Cont1 0.053 Ohm P
Bond/Cont2 0.054 Ohm P
Bond/Cont3 0.056 Ohm P
Insulation >50.0 MEG P
Operation 0.097 kVA P
Earth Leak 0.270 mA P

Test Date: 15/08/2009 Test Time: 15:27 User: PETE
Appliance: 028 31347 T1000 PANARAY CONT
Visual Inspection P
Bond/Cont1 0.055 Ohm P
Bond/Cont2 0.054 Ohm P
Bond/Cont3 0.053 Ohm P
Insulation >50.0 MEG P
Operation 0.055 kVA P
Earth Leak 0.250 mA P

Signature: _____

PL Newman

Date: _____

15/8/09